



Industrie Service

# CERTIFICATE

11 05 91325 002

revision 01

**Pennine Systems Ltd.**  
**Crossley Works, Stockfield Mount, Off Peel Str.**  
**Chadderton, Oldham, GB-OL9 9LR**

Based on the test report

A 1906-00/11

on the initial type test according to

**EN 1856-2:2009**

and in connection with a periodical surveillance of the production/product and the quality control according to the certification regulations of TÜV SÜD Industrie Service GmbH this certificate permits to mark the

**connecting flue pipe**  
**type PREMIER**

DN 200	EN 1856-2	T600 N1 D Vm L80120 G600 NM
DN 180	EN 1856-2	T600 N1 D Vm L80120 G540 NM
DN 175	EN 1856-2	T600 N1 D Vm L80120 G525 NM
DN 150	EN 1856-2	T600 N1 D Vm L80120 G450 NM
DN 125	EN 1856-2	T600 N1 D Vm L80120 G375 NM
DN 100	EN 1856-2	T600 N1 D Vm L80100 G375 NM

manufactured by

**Pennine Systems Ltd.**  
**Crossley Works, Stockfield Mount, Off Peel Str.**  
**Chadderton, Oldham, GB-OL9 9LR**

with the TÜV mark as shown.



Munich, 2012-01-02

*Johannes Stajglechner*  
 .....  
 Johannes Stajglechner

# CERTIFICATE

11 05 91325 001



Industrie Service

**Pennine Systems Ltd.  
Crossley Works, Stockfield Mount Off Peel str.  
Chadderton, Oldham, GB-OL9 9LR**

Based on the test report

A 1905-00/11

on the initial type test according to

**EN 1856-2:2009**

and in connection with a periodical surveillance of the production/product and the quality control according to the certification regulations of TÜV SÜD Industrie Service GmbH this certificate permits to mark the

**single wall liner  
type PREMIER**

**model 1 EN 1856-2 T600 N1 D Vm L50060 G  
model 2 EN 1856-2 T600 N1 D Vm L50100 G**

manufactured by

**Pennine Systems Ltd.  
Crossley Works, Stockfield Mount Off Peel str.  
Chadderton, Oldham, GB-OL9 9LR**

with the TÜV mark as shown.



Munich, 2011-05-12

Johannes Steiglechner

ZERTIFIKAT ◆ CERTIFICATE ◆ 認証証書 ◆ CERTIFICADO ◆ CERTIFICAT

Notified Body  
Nr. 0036



## Certificate of conformity of the factory production control

0036 CPR 91325 003  
Revision 02

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

### Connecting flue pipe type Premier One models

model 1	EN 1856-2	T600 N1 D Vm L80060 GXXX NM
model 2	EN 1856-2	T600 N1 D Vm L80100 GXXX NM
model 3	EN 1856-2	T600 N1 D Vm L80120 GXXX NM

*for details of classification see page 2*

produced by

**Pennine Systems Ltd.**  
**Crossley Works, Stockfield Mount, Off Peel Str.**  
**Chadderton, Oldham, GB-OL9 9LR**

in the manufacturing plant

**Pennine Systems Ltd.**  
**Chadderton, Oldham, GB-OL9 9LR**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

**EN 1856-2:2009-06**

under system 2+ are applied and that the factory production control fulfils all the prescribed requirements set out above.

The determination of the product type on the basis of type testing is documented in the following report: TÜV SÜD Industrie Service GmbH no. A 1907-00/11.

This certificate was first issued on 2011-02-28 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Munich, 2014-03-18

Johannes Steiglechner  
Leiter Zertifizierungsstelle Bauprodukte (EG)



Connecting flue pipe  
Premier One  
models

EN 1856-2: 2009

model 1

DN 200  
DN 180  
DN 175  
DN 150  
DN 130  
DN 125  
DN 100

T600 N1 D Vm L80060 G600 NM  
T600 N1 D Vm L80060 G540 NM  
T600 N1 D Vm L80060 G525 NM  
T600 N1 D Vm L80060 G450 NM  
T600 N1 D Vm L80060 G390 NM  
T600 N1 D Vm L80060 G375 NM  
T600 N1 D Vm L80060 G375 NM

model 2

DN 200  
DN 180  
DN 175  
DN 150  
DN 130  
DN 125  
DN 100

T600 N1 D Vm L80100 G600 NM  
T600 N1 D Vm L80100 G540 NM  
T600 N1 D Vm L80100 G525 NM  
T600 N1 D Vm L80100 G450 NM  
T600 N1 D Vm L80100 G390 NM  
T600 N1 D Vm L80100 G375 NM  
T600 N1 D Vm L80100 G375 NM

model 3

DN 200  
DN 180  
DN 175  
DN 150  
DN 130  
DN 125  
DN 100

T600 N1 D Vm L80120 G600 NM  
T600 N1 D Vm L80120 G540 NM  
T600 N1 D Vm L80120 G525 NM  
T600 N1 D Vm L80120 G450 NM  
T600 N1 D Vm L80120 G390 NM  
T600 N1 D Vm L80120 G375 NM  
T600 N1 D Vm L80120 G375 NM

Notified Body  
Nr. 0036



Industrie Service

## Certificate of conformity of the factory production control

0036 CPR 91325 018

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

### Connecting flue pipe type Premier One Plus models

model 1	EN 1856-2	T600 N1 D Vm L80060 GXXX NM
model 2	EN 1856-2	T600 N1 D Vm L80100 GXXX NM
model 3	EN 1856-2	T600 N1 D Vm L80120 GXXX NM

*for details of classification see page 2*

produced by

**Pennine Systems Ltd.**  
**Crossley Works, Stockfield Mount, Off Peel Str.**  
**Chadderton, Oldham, GB-OL9 9LR**

in the manufacturing plant

**Pennine Systems Ltd.**  
**Chadderton, Oldham, GB-OL9 9LR**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

**EN 1856-2:2009-06**

under system 2+ are applied and that the factory production control fulfils all the prescribed requirements set out above.

The determination of the product type on the basis of type testing is documented in the following report: TÜV SÜD Industrie Service GmbH no. A 1907-00/11.

This certificate was first issued on 2014-03-18 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Munich, 2014-03-18

Johannes Steglechner  
Leiter Zertifizierungsstelle Bauprodukte (EG)



Industrie Service

Connecting flue pipe  
Premier One Plus  
models

EN 1856-2: 2009

model 1

DN 200  
DN 180  
DN 175  
DN 150  
DN 130  
DN 125  
DN 100

T600 N1 D Vm L80060 G600 NM  
T600 N1 D Vm L80060 G540 NM  
T600 N1 D Vm L80060 G525 NM  
T600 N1 D Vm L80060 G450 NM  
T600 N1 D Vm L80060 G390 NM  
T600 N1 D Vm L80060 G375 NM  
T600 N1 D Vm L80060 G375 NM

model 2

DN 200  
DN 180  
DN 175  
DN 150  
DN 130  
DN 125  
DN 100

T600 N1 D Vm L80100 G600 NM  
T600 N1 D Vm L80100 G540 NM  
T600 N1 D Vm L80100 G525 NM  
T600 N1 D Vm L80100 G450 NM  
T600 N1 D Vm L80100 G390 NM  
T600 N1 D Vm L80100 G375 NM  
T600 N1 D Vm L80100 G375 NM

model 3

DN 200  
DN 180  
DN 175  
DN 150  
DN 130  
DN 125  
DN 100

T600 N1 D Vm L80120 G600 NM  
T600 N1 D Vm L80120 G540 NM  
T600 N1 D Vm L80120 G525 NM  
T600 N1 D Vm L80120 G450 NM  
T600 N1 D Vm L80120 G390 NM  
T600 N1 D Vm L80120 G375 NM  
T600 N1 D Vm L80120 G375 NM